

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:31 pm

**PWS ID:** UTAH20074      **Name:** PAINTED ROCK CAMPGROUND  
**Legal Contact:** BLM - UTAH STATE OFFICE      **Rating:** Approved  
TRENT DUNCAN      **Rating Date:** 09/02/2008  
**Address:** PO BOX 45155      **Activity Status:** Active  
SALT LAKE CITY, UT 84145-0155  
**Phone Number:** 801-539-4001  
**City Served (Area):**  
**County:** SANPETE COUNTY  
**System Type:** Non-community      **Last Inv Update:** 07/20/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 06/05/2008      **Total Dsgn Cap:**  
**Population:** 50      **Surveyor:** JOHN H OAKESON      **Total Emerg Cap:**  
**Oper Period:** 5/15 to 9/30

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	DUNCAN, TRENT	CIVIL ENGINEER	435-539-4090		TRENT_DUNCAN@BLM.GC

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	10
			10 Total Svc Connections

### Storage

**Total Storage:** 20,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	PAINTED ROCKS 20K FIBERGLASS	Underground	20,000 GAL	Fiberglass		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	2006 WELL	Active	WL		25 GPM	15 GPM	Yes	GW	Seasonal	5/15 to 9/30	

\*Reports measured flow for wells, approved design capacity for all other sources.